## Baugruppe VR ¾" EN1717





## Baugruppe VR <sup>3</sup>/<sub>4</sub>" EN1717 (6-8-10 bar)

The Baugruppe is installed in connection with domestic water heaters (fired by electric, gas or oil) and must be fitted to the cold water inlet. The Baugruppe can be mounted vertically or at a right angle (by swapping the 3 safety valve).

The Boiler Safety Unit consists of a:

- shut-off valve (for closing the cold water inlet)
- built-in check valve (prevents recirculation of warm water into the cold water inlet)
- safety valve <sup>3</sup>/<sub>4</sub>" (valve outlet must always point downward)
- arrow flow indication
- test plug

Continuous operating temperature max. 65°C/peak load max. 90°C (1 hour). Max. cap. 2.460 l/h at 1 bar (100kPa) differential pressure.


Before installing the Baugruppe please check our installation instructions.


## Safety


Check whether the max. capacity and the opening pressure that are indicated on the valve match the values of the system.

## Norm:

NEN-EN 1491 (safety valve) NEN-EN 1717 (test plug) NEN-EN 13959 (check valve)







kiwa CE

Baugruppe VR ¾" EN1717		
Article number	Set pressure bar	Max. capacity water heater kW
1211-0-06-01	6	150
1211-0-08-01	8	150
1211-0-10-01	10	150



Tel. E-mail Internet

+31 (0)182 503 100 info@pentecbv.nl www.duco.nl www.pentecbv.nl